

STATE OF MICHIGAN

Office of the Michigan Public Utilities Commission, } ss.

I, Albert A. Wagner, Secretary of the Michigan Public Utilities Commission

Do Hereby Certify, That I have compared the annexed copy of Permit ED2-8-578

4311

with the original

recorded in File ED2-8-578

and that it is a true and correct transcript therefrom, and of the whole of such original.

In Testimony Whereof, I have hereunto set my hand and affixed the seal of the Commission, at Lansing, this 5th day of November in the year of our Lord one thousand nine hundred thirty-seven.

Albert A. Wagner
Secretary Michigan Public Utilities Commission

4311
Recorded R/W File No. 33222
p. 61

STATE OF MICHIGAN
BEFORE MICHIGAN PUBLIC UTILITIES COMMISSION

Standard Railroad Wire-Crossing Permit No. ED2-8-578

In Re Application of **Detroit Edison Company**
(Detroit)

Pursuant to Act No. 171 of the Session Laws of 1893, as amended, application having been made to Michigan Public Utilities Commission by said **Detroit Edison Company**

for permission to string wires across the tracks of the **Pere Marquette Ry.**

and said **Detroit Edison Company**

having conformed to the Commission's rules governing the filing of notices and issuing of permits for the construction of electrical lines and said rail company having waived the right of notice and hearing provided for in said act

THEREFORE, It is ordered that said **Detroit Edison Company**

be permitted to string the following described wires across the tracks of said railroad at the following described place: **In Village**

of Minden City, in private right-of-way, 900 ft. south of Main St.
Sanilac County in N.W. 1/4 Sec. 12, 14N, R 14E, Minden Twp.

3-#4 H. TBWP solid copper wires @ 4800 volts

as indicated on the attached plans, when, as and if approved.

At the point of crossing said wires shall be constructed in accordance with this Commission's rules and regulations.

Given under our hands and the Official Seal of this Commission at the City of Lansing, State of Michigan, this **5th** day of **November** A. D. 19**37**

MICHIGAN PUBLIC UTILITIES COMMISSION
By

Paul H. Todd

Chairman,

Joseph M. Donnelly

Commissioner,

Glenwood C. Fuller

Commissioner,

Charles S. Porritt

Commissioner,

Howell Van Auken

Commissioner.

Countersigned

Albert A. Wagner

Secretary


Recorded R/O File No. 33222 p 61

PERE MARQUETTE RAILWAY COMPANY

General Motors Building
DETROIT, MICH.

G. W. TROUT
Signal Engineer and Superintendent Telegraph
H. C. LORENZEN
Asst. Signal Engineer

October 23, 1937.



The Detroit Edison Company,
2000 Second Avenue,
Detroit, Mich.


Attention: Mr. T.L. Hinks, Right-of-Way Agent.

Gentlemen:

This will acknowledge receipt of your application of October 22nd requesting waiver of hearing before the Michigan Public Utilities Commission on behalf of The Detroit Edison Company for permission to construct and maintain an aerial wire line crossing over the tracks of the Pere Marquette Railway Company approximately 900 feet South of Main Street, Village of Minden City, Sanilac County, Michigan; crossing to consist of one circuit of three #4 T.B.W.P. solid copper wires carrying 4800 volts.

The Pere Marquette Railway Company hereby waives hearing before the Michigan Public Utilities Commission for permission to construct and maintain the above aerial wire line crossing, with the provision that the construction and maintenance shall conform to the requirements of the Michigan Public Utilities Commission for such aerial wire line crossings.

Very truly yours,


Signal Engineer.
Supt. Telegraph.

W.

Original forwarded direct to the Michigan Public Utilities Commission at Lansing, Michigan.

RECORDED RIGHT OF WAY NO.

3322

101

R-1807
2-8-578

THIS RAILROAD CROSSING IS OF A LINE EXTENSION LESS THAN ONE MILE LONG AND WITHIN THE CORPORATE LIMITS OF A VILLAGE SO THAT THERE IS NO CORRESPONDING APPLICATION FOR A DISTRIBUTION LINE EXTENSION PERMIT.

RX 1807

THE DETROIT EDISON CO.

PLAN SUBMITTED TO MICHIGAN PUBLIC UTILITIES COMMISSION FOR OVERHEAD LINE CROSSING

RECEIVED MICHIGAN PUBLIC UTILITIES COMMISSION OCT 25 1937

OVER PERE MARQUETTE (SIDING) R R
IN PRIVATE PROPERTY APPROX 905' SOUTH OF MAIN STREET

CITY OF VILLAGE OF MINDEN CITY NW 1/4 SECTION 12
MINDEN TOWNSHIP T. 14N R. 14E SANILAC COUNTY

CIRCUITS					CONDUCTORS		
NUMBER	VOLTAGE	CYCLES	PHASE	USE	WIRES	SIZE	KIND
ONE	4800	60	3	DIST	3	#4	H TRWP SOLID COPPER

POLES						
LOCATION	LENGTH	MATERIAL	MIN CIRCUMFERENCE		DEPTH OF SETTING	KIND OF SETTING
			AT TOP	AT GROUND		
A-B	40	WESTERN CEDAR	23"	39"	6'	CLAY SOIL
C	40	"	23"	40"	6'	"

NOTE

MATERIALS SHALL BE AS NOTED IN THE DETROIT EDISON COMPANY'S STANDARD SPECIFICATIONS FOR OVERHEAD LINE CONSTRUCTION AT RAILROAD CROSSINGS ISSUED DECEMBER 23, 1935.


PURPOSE OF LINE

EXTENSION OF DISTRIBUTION TO PROVIDE SERVICE TO THE STA. OIL CO.


DRAWN BY W.S.M. DATE 10-19-37 CHECKED BY J.L. DATE 10-19-37

APPROVED FOR MICHIGAN PUBLIC UTILITIES COMMISSION
C. R. Windsor
CHIEF ENGINEER
ED2-8-578
FILE DATE OCT 25 1937

PROPOSED 3#4 4800VOLT WIRES (IMMEDIATE)




POLE B LOOKING SOUTH




POLE B LOOKING EAST


PROPOSED 3#4 4800 VOLT WIRES (IMMEDIATE)




POLE C LOOKING SOUTH



POLE C LOOKING EAST



PLAN OF CROSSING



ELEVATION LOOKING EAST

RECORDED ROW FILE# R33222P61

BOWMAN - PI HURON

DRAFTING & SURVEYING BUREAU RX 1807

RECORDED RIGHT OF WAY NO. 33222
P61