Tubl	JETRALIT	EDICON	COMPANY
RECEIVED	PEIROII	PD120N	OOMPANI
MICHIGAN PUBLIC SERVICE		ECOND AVENU	

MICHIGAN PUBLIC SERVICE COMMISSION

DEC 7 1973

DETROIT, MICHIGAN 48226

December 5, 1973

PUBLIC UTILITIES DIVISION

מאריננ

Michigan Public Service Commission Lansing, Michigan 48913

Gentlemen:

I. C. Gilkey - Office Supervisor - Transmission & Distribution Dept. of The Detroit Edison Company, Detroit, Michigan, hereby certify that the wire crossing covered by Wire Crossing Permit No. ED2-8-7237 , has been constructed in accordance with specifications of the Michigan Public Service Commission and construction standards of The Detroit Edison Company, approved by Michigan Public Service Commission on July 19, 1939, File ED2-9.01, and that this crossing will be maintained as provided in such specifications and construction standards.

Yours very truly,

		My Commission Expires June 5, 1976	
Railroad	Grand Trunk Western	_ County, Michigan.	
		Robert R. Tewksbury Notary Public, Oakland	
	St. Clair County	AM I	
Location S	E 1/4 of Section 10 Port Huron Township		
W 110.	Span B-C	Supecified and swork to belote, me this	

RETURN COPY OF THIS AFFIDAVIT TO REAL ESTATE AND RIGHTS OF WAY DEPT.

THE DETROIT EDISON

2000 SECOND AVENUE

D.O. NO.

DETROIT, MICHIGAN HSPRECEIVED

March 27, 1973

Michigan Public Service Commission Lansing 13, Michigan

Gentlemen:

MICHIGAN PUBLIC SERVICE COMMISSION

MAR 2 8 1973

PUBLIC UTILITIES DIVISION

The Detroit Edison Company, Detroit, Michigan, hereby makes application for authority to string the following wires over the tracks of the Grand Trunk Western Railroad Company in the City of Port Huron, in the Southeast 1/4 of Section 10, Port Huron Township, St. Clair County, Michigan.

Span B-C

Three No. O A 4800-volt wires and One No. O B 120/240-volt wire, and Three No. 0 A 120/240-volt wires located in Court Street, 90 feet East of Fourth Street.

The proposed wire crossing will be constructed in accordance with specifications of the Michigan Public Service Commission and the construction standards of The Detroit Edison Company, approved by the Michigan Public Service Commission on July 19, 1939, File ED 2-9.01.

- Enclosed is a waiver of hearing granted by the Railroad Company.
- Waiver of hearing by the Railroad Company is covered by blanket waiver.
- This application covers reconstruction of existing crossing and will cancel and supersede wire crossing permit No. ED2-8-4718 dated 6-10-60
- This is a new crossing.

HB:md

Reference number of construction drawing is RX- 1418D

Yours very truly,

Permit No. ED2-8-7237

WCarnold /dd

W. C. Arnold, Director Real Estate and Rights of Way Department

Check in circle indicates statement applicable.

ESCORDED RIGHT OF WAY NO.

2000 SECOND AVENUE DETROIT MICHIGAN 48226

TO:

March 27, 1973

Mr. R. D. Dykman, Engineer of Surveys and Construction Grand Trunk Hestern Emilrond Company East Hall Street, Depot Battle Breek, Michigan 49016

Proposed Overhead Wire Crossing:

Three No. C A 4800-volt wires and One No. O B 120/240-volt wire and Three No. O A 120/240-volt wires. (Spin B-C)

Specific Location

In Court Street, 90 feet East of Fourth Street.

R.R. Valuation Station	R. R. Mile Post	_
City/vinage Fort Muron	Township Fort Buron, SE 1/4 of Sec. 10	
County St. Clair Detroi	it Edison Plan Attached RK-1418D	-、
This is a New Crossing	This is a Reconstruction of Existing Crossing	_ `
Previous Agreement Information (if a Previous Railroad File No. 47	ny) Date(R. R. Plan)	
	Waiver of Hearing Requested	_
C	dance with the rules and regulations of the Michigan Public Service	

Hitz dead

W. C. Armold, Director
Real Estate and Rights of Way Department

JONNED RICHT OF WAY HOUT 1636

Submit One (1) Copy for h Span to Real Estate and Rights or Way Dept.

D.O.	No.	в-76928	· 1113 - L
Date		3/20/73	

RAILROAD CROSSING DATA SHEET

THE DETROIT EDISON COMPANY

RX 1418D

Span B≟C

Railroad:

Revision of RX ____1418C

Grand Trunk Western

M.P.S.C. Permit and Date ED2-8-4718

Facilities:

Three #0 A 4800 V One #0 B 120/240 V Three #0 A 120/240 V

Location:

in Court St. 90' E. of Fourth St. in the City of Port Huron in the S.E. & of Section 10, Port Huron Township T6N, R17E, St. Clair County.

System Engineering Dept.

no 4730-1803

June 10, 1960

GT-PONTIAL

ALCORDED RIGHT OF WAY NO 34 636

THE DETROIT EDISON COMPANY

RECEIVED
MICHIGAN PUBLIC SERVICE
COMMISSION

DEC 7 1973

2000 SECOND AVENUE
DETROIT, MICHIGAN 48226

December 5, 1973

Michigan Publiqueservice Commission Lansing, Michigan 48913

Gentlemen:

of The Detroit Edison Company, Detroit, Michigan, hereby certify that the wire crossing covered by Wire Crossing Permit No. ED2 -8-7238

issued 6-1-73, has been constructed in accordance with specifications of the Michigan Public Service Commission and construction standards of The Detroit Edison Company, approved by Michigan Public Service Commission on July 19, 1939, File ED2-9.01, and that this crossing will be maintained as provided in such specifications and construction standards.

Yours very truly, Suckey

RX No.	l418D Span E-F	_ Subscribed and sworn t	o before me this
Location 2	E 1/4 of Section 10 Port Huron Township	5th XXX day of Dec	ember , 19 <u>73</u>
	St. Clair County	K+N.	1
		Robert R. Notary Public,	Tewksbury Oakland
Railroad _	Grand Trunk Western	_ County, Michigan.	
•		My Commission Expires	June 5, 1976

RETURN COPY OF THIS AFFIDAVIT TO REAL ESTATE AND RIGHTS OF WAY DEPT.

ELEPHONE 962-2100

R/E & R/W DEPT: The Detroit Edison Company

2000 SECOND AVENUE

DETROIT, MICHIGAN

4RECEIVED D.O. No. B-76928
MICHIGAN PUBLIC SERVICE
3-20-73 COMMISSION

March 27, 1973

Michigan Public Service Commission Lansing 13. Michigan

MAR 2 8 1973

PUBLIC UTILITIES DIVISION

Gentlemen:

The Detroit Edison Company, Detroit, Michigan, hereby makes application for authority to string the following wires over the tracks of the Grand Trunk Western Reilroad Company in the City of Port Hiron, in the Southeast 1/4 of Section 10, Port Huron Township, St. Clair County, Michigan.

Span E-F

Three No. O A 4800-volt wires and Four No. 2 WP 120/240-volt wires located in Court Street, 310 feet East of Fourth Street.

The proposed wire crossing will be constructed in accordance with specifications of the Michigan Public Service Commission and the construction standards of The Detroit Edison Company, approved by the Michigan Public Service Commission on July 19, 1939, File ED 2-9.01.

- Enclosed is a waiver of hearing granted by the Railroad Company.
- Waiver of hearing by the Railroad Company is covered by blanket waiver.
- This application covers reconstruction of existing crossing and will cancel and supersede wire crossing permit No. xn2-x-3614 dated 4-19-55
- This is a new crossing.

Reference number of construction drawing is RX- 1418D HB:dmd

Yours very truly,

Permit No.__

ED2-8-7238

W.C. Quoed/dd

W. C. Arnold, Director Real Estate and Rights of Way Department

Check in circle indicates statement applicable.

RECORDED RICHT OF WAY NO. 24654

TO:

Merch 27, 1973

Mr. R. D. Dykann Engineer of Surveys and Construction Grand Trunk Western Railread Company East Hall Street Depot Battle Creek, Michigan 49016

Proposed Overhead Wire Crossing:

Three Ho. O A 4800-wolt wires and Four No. 2 WP 120/240-wolt wires. (Span E-P)

	RFCORDED
Specific Location	BIGHT
In Court Street, 310 feet East of Fourth Street.	OF WAY NO.
R.R. Valuation Station R. R. Mile Post	4634
City/Village Township	% [,
County Detroit Edison Plan Attached Ex-1418D	
St. Clair This is a New Crossing This is a Reconstruction of Existing Crossing	
Previous Agreement Information (if any) Date(R.R. Plan)	· · · · · · · · · · · · · · · · · · ·
Previous Railroad File Ro. 4730-1803 Blanket Waiver of Hearing Covers Waiver of Hearing Requested (Waiver of Hearing to be mailed to applicant listed below)	<u>.</u>
All construction will be done in accordance with the rules and regulations of the Michigan Public Ser Commission. (U. G. Arrold / dl.)	rvice

W. C. Arnold, Director Real Estate and Rights of Way Department

D.O. No. <u>B-76928</u>	
-------------------------	--

* Date 3/20/73

THE DETROIT EDISON COMPANY

RAILROAD CROSSING DATA SHEET

RX 1418D

Span <u>E-</u>F

Die RIM Kier RIM 3-21-736

Railroad:

Revision of RX 1418C

Grand Trunk Western

M.P.S.C. Permit and Date ED2-8-3614

Facilities:

Three #0 A 4800 V

Four #2 WP 120/240 V

Location:

in Court St. 310' E. of Fourth St. in the City of Port Huron, in the S.E. $\frac{1}{2}$ of Section 10, Port Huron Township, T6N, R17E,

April 19, 1955

St. Clair County.

System Engineering Dept.

Date 3/20/73

By C.J. Schepperly am

Therewo Radione File

no 4730-1803

GT-PONTIAC