



Date: May 30, 2014

To: Fernando Guevara
Real Estate and Rights of Way
ITC

From: Connor Denman
Engineering
ITC

Subject: **UGL0143908/CU-754**
CE Reference No. Gladwin/Beaverton/1023346492/Hall
Proposed distribution work in area of METC 120 kV Transmission Bard Road-Warren Lane 6L

Consumers Energy is proposing to install a Single Phase Line and a 40-6 distribution pole near and under METC's 120 kV Line 6L, transmission tower 006L9382.

This request is hereby under the following conditions:

1. CE LVD conductors not to exceed 25' from the ground at conductor crossing at winter ambient temperature of 50° F
2. CE LVD pole be placed at least 20' west from the existing ITC pole 006L9382

Approved By:

A handwritten signature in black ink, appearing to read 'Connor Denman', is written over a horizontal line.

Connor Denman
Associate Engineer



Real Estate and Claims Division

**Project No: UGL0143908
CU-754**

Date: May 16, 2014

To: Ashley Dupree (Towers Group)

From: Fernando Guevara (Real Estate)

Subject: Proposed Distribution Work in Area of METC 138kV Transmission Line – Bard Road
Warren Line, 6L

CE Reference No. Gladwin/Beaverton/1023346492/Hall

Consumers is proposing to install a Single Phase line and a 40-6 distribution pole near and under METC 138 kV-Bard Road Warren Lane Line 6L that runs in a northerly/southerly direction, near structure # 006L9382. Furthermore, pursuant to the Amended and Restated Easement Agreement, METC/ITC needs to submit a response letter to CE by **June, 3 2014**.

Please review and return to my attention with your recommendations/comments.

Attachments

A CMS Energy Company

May 15, 2014

Michigan Electric Transmission Company,
an ITC Company
Attn: Fernando Guevara
27175 Energy Way
Novi, MI 48377-3639

Attention: Executive Vice President and Chief Operating Officer

SUBJECT: Proposed: Distribution work in area of METC
138kV Transmission Line - Bard Road Warren Lane 6L
Reference: Gladwin/Beaverton/1023346492/Hall

REFERENCE: Amended and Restated Easement Agreement (the "Agreement") dated April 29, 2002, between Consumers Energy Company ("Consumers") and Michigan Electric Transmission Company, now Michigan Electric Transmission Company, LLC ("METC")

Pursuant to Section 7.1 of the Agreement, Consumers hereby notifies METC that Consumers is proposing to install a Single Phase of #4ACSR Conductor distribution line that runs under and near an existing METC transmission line on certain land that METC has an interest under the Agreement. The location of the land on which said work will be performed, and a further description of the intended use, are set forth on "Annex A", attached to this letter.

Under said Section 7.1 of the Agreement, METC must within 30 days of this notice notify Consumers, as "Initiating User," of whether or not METC approves the proposed use as a Compatible Use. If you do not notify us either way within 30 days of this notice, then, as provided in said Section 7.1, METC will be deemed to have approved the proposed use as being a Compatible Use. We would appreciate, however, receiving METC's express approval of the proposed use as being a Compatible Use as soon as possible so that we can start work without delay.

Page Two

Reference No: Gladwin/Beaverton/1023346492/Hall

This letter is being sent to you in duplicate. If METC agrees that the proposed use is a Compatible Use, please indicate that by signing and returning a copy of this letter to us as soon as possible, so that we can immediately proceed with construction. The other copy is for your records.

Sincerely,



Marcia A Losert, EP7-455
Real Estate Technical Analyst
Consumers Energy Company
One Energy Plaza
Jackson, MI 49201

MICHIGAN ELECTRIC TRANSMISSION COMPANY, LLC, a Michigan limited liability company

By: ITC Holdings Corp., its manager

By: _____

Name: Christine Mason Soneral

Title: Vice President and General Counsel-Utility Operations of ITC Holdings Corp.



| DEPARTMENT | REVIEWED | DATE |
|------------------|---------------|----------------|
| Asset Management | C.J.D. | 5/30/14 |
| Engineering | | |
| Real Estate | | |
| Legal | | |
| Planning | | |

ANNEX A

Reference No: Gladwin/Beaverton/1023346492/Hall

LAND TO BE IMPACTED:

That certain parcel of land in the State of Michigan, described as follows:

Located in Section 19, T17N, R2W of Beaverton Township, Gladwin County, Michigan.

PROPOSED USE:

Consumers is proposing to install Single Phase line and a 40-6 distribution pole near and under METC 138 kV – Bard Road Warren Lane Line 6L that runs in an northerly/southerly direction.

Transmission line Pole No. 9382

Please see specifications on attached forms 391 and drawings.

TRACT ID # 455-D6-3

**CONSUMERS ENERGY
NOTIFICATION OF PROPOSED LINE CONSTRUCTION
REQUIRING COORDINATION WITH HVD AND/OR TRANSMISSION LINES**

Send two (2) copies to:

HVD Lines Design and Standards

Att: Vangie Harvey

Jackson, Michigan

| |
|---|
| TO BE FILLED IN BY SYSTEM OWNER / ENGINEER / CES |
| Headquarters <u>Midland</u> |
| Notification No. <u>1023346492</u> |
| Date <u>03/12/2014</u> |

PROPOSED DISTRIBUTION CONSTRUCTION

Sketch Attached Yes No

Primary:

Voltage 4800 Phase single

No. of Wires 2 Crossarms Per Pole 2

Wire Size 4 acsr Length of Crossarms 8'

Distance Below Transmission 11'

Skip-Span Yes No

Secondary:

No. of Wires _____ Wire Size _____

Other Details: _____

| |
|--|
| PROPOSED COMMUNICATION CONSTRUCTION TO BE FILLED IN BY FIELD TECHNICIAN |
| Cable Dia. _____ |
| Weight/ft. _____ |
| Strand Size _____ |
| Tension _____ |
| Pole Attachment Height _____ |
| Map # _____ Pole # _____ |

EXISTING DISTRIBUTION FACILITIES

Description:

LOCATION

Township Beaverton

County gladwin

Town 17 Range 02 Section 19

Transmission Line Involved Bard Rd Warren Ln

Transmssion Pole No. 9382

| |
|--|
| TO BE FILLED IN BY HVD LINES DESIGN AND STANDARDS OR METC |
| Clearance/Attachment Approved <input type="checkbox"/> |
| Clearance/Attachment NOT Approved <input type="checkbox"/> |
| Clearance requires further verification <input type="checkbox"/> Yes <input type="checkbox"/> No with Power System Analysis |
| Structural Integrity - Engineering Required <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Calculated assuming STE rating of _____ °F Cond Temp |
| Checked By _____ Date _____ |
| Order No. _____ |

REMARKS:

Prepared By Robert H. Hall Date _____
System Planning and Performance / Electric Service

Reviewed By Evangelie Date 5/14/14
HVD Lines Design and Standards

Reviewed By _____ Date _____
METC

METC lines are subject to the easement rights of METC. Your request has been forwarded to Real Estate for processing and will require a 30-day period prior to approval.

T18M

BUCK

GROU TWP.

BEAVERTON LINE

BEAVERTON

T17M

BARD RD.-WARREN LINE

DALE RD

BEAVERTON TWP
BEAVERTON LINE

TOBACCO TWP.

CLARE

GLADWIN

GLADWIN

TO WARREN
MIDLAND
TO WARREN R2W

R1W

REFER TO EAST ZONE FOR CONTINUATION OF LINES SOUTH

TO



