


APPLICATION FOR RIGHT OF WAY
D E CO FORM MS 80



No. 9256

TO RIGHT OF WAY AGENT

Date Nov. 23, 1928

Please secure right of way as follows:

Location (See also map attached herewith) On Main Street approximately 60' S. of Seventh, on Seventh, G.T.R.F. to Troy; on Troy, 7th to Lincoln; On Lincoln, Main to Troy; on Knowles, 7th to A.S; in A.N. of Lincoln, Troy to Knowles; in A.E. of Troy, 7th to A.S., in Royal Oak, Michigan.

Kind of lines to be built Install 15 and 12 - 4" fibre ducts, manholes and drains for same, as per B/P #U380-653 and #U380-675.

For what purpose This conduit to provide for transmission cables to new Royal Oak Sub. and transformer feed cable between new and old Substations; also for distribution cables from old sub station.

Permit desired as soon as possible from the City of Royal Oak, Michigan.

Signed [Signature]
Department Underground Lines
TW:EA

NOV 29 1928

REPORT OF RIGHT OF WAY AGENT

Permit No. _____ Secured as follows: _____

Permissions granted as per attached correspondence.

Remarks (all correspondence attached)

Date December 1st 1928 Signed [Signature]

RIGHT OF WAY FILE No. 7791

RIGHT OF WAY FILE No. 7791

December 1st, 1928

Mr. E. M. Shafter, City Engineer
City of Royal Oak
Michigan

Dear Sir:-

We have your letter dated November 30th, authorizing us to go ahead on our underground job in the neighborhood of our new Royal Oak Substation permit for which was requested in our letter of November 26th, this permit being granted subject to certain alterations also outlined in your letter.

We agree to revise our plans in accord with these alterations.

Yours very truly,

Asst. Right of Way Agent.

GBH-JB



CITY OF ROYAL OAK
MICHIGAN

November 30, 1928

Detroit Edison Company
2000 Second Boulevard
Detroit, Michigan

Attention of Mr. T. L. Hinks

Gentlemen:

Your request of November 26 for permission to install 4-inch fibre ducts and necessary manholes with drains for same has been referred to this office for investigation and reply.

On Seventh Street between Main and Troy Streets we would suggest that the location of the conduit be changed from 21 feet north of the south property line, as indicated on your blueprint, to a location of 10 feet north of the south property line for the reason that we are endeavoring to follow, as closely as possible, a predetermined plan for the location of public utilities.

On Troy Street between Seventh Street and Lincoln Avenue it is suggested that the conduit be located 1 foot west of the existing sidewalk on the east side of the street instead of 3 feet east of the east curb line as indicated on your blueprint. This change is asked also to conform more closely to the location plan adopted for such utilities.

On Lincoln Avenue between Main and Troy Streets the proposed location of 1 foot north of the south edge of the north sidewalk will be all right if the sidewalk is properly protected during the installation of the conduit.

The proposed locations of the 4-inch fibre ducts in the following streets are approved as shown on your blueprints:

Knowles Street from Seventh Street to the alley
south of Seventh.

East and west alley between Seventh and Lincoln
extending from Troy to Knowles.
Alley east of Troy from Seventh to alley south
of Seventh.
Manhole in Main Street located approximately 60
feet south of Seventh Street.
Lincoln Avenue from Main Street to Troy Street.

Permission for the construction of the fibre
ducts in the locations outlined above is granted under
the following conditions:

1. That proper care will be exercised to protect all
underground structures and that you will be liable for
all damage thereto.
2. That the trench opened for this work shall be back-
filled by machine tamping for the entire depth of the
excavation, or by flushing if the soil conditions permit.
3. That you will bear the entire cost of pavement repairs.
4. That the work shall be done in such sequence as to
maintain traffic at all times.
5. That you will provide gravel or cinders as a surface
course in such places as are necessary to be kept open
to traffic until such time as it would be feasible to
replace concrete.
6. The City of Royal Oak is not liable in any way
whatsoever for damage suits or other claims arising
through these operations.
7. The City of Royal Oak shall have the right to place
an inspector on the job if deemed advisable and the cost
of such inspection shall be borne by the Detroit Edison
Company.

Acknowledgment of this letter, agreeing to
the stipulations set forth, will be your authorization
to proceed with the work.

Very truly yours,

CITY OF ROYAL OAK

E. M. Shafter

City Engineer.

EMS:R

November 26th, 1928

Mr. R. J. Whitney, City Manager
City of Royal Oak
Michigan

Dear Sir:-

The Detroit Edison Company respectfully asks your permission to install 15 and 12 - 4" fibre ducts and necessary manholes, with drains for same, as follows:-

In Main Street approximately 60' South of Seventh (manhole);
In Seventh, from Grand Trunk Railroad to Troy;
In Troy, from Seventh to Lincoln;
In Lincoln, from Main to Troy;
In Knowles, from Seventh to alley South;
In alley North of Lincoln, from Troy to Knowles;
In alley East of Troy, from Seventh to alley South.

All of the above to be in the City of Royal Oak and is to provide for transmission cables to our new Royal Oak Substation and transformer feed cable between new and old Substations; also for distribution cables from old Substation.

We are enclosing two blue prints #U380-655 and #U380-675 showing exact location and other details of the proposed installation.

Will you kindly mail the necessary permit to us so that we may start the work as soon as possible?

Yours truly,

Right of Way Agent.

TLH-JB

NOV 28 1928
Mr. J. Brien
from Royal Oak
Michigan
12/1/28
4/6/28